

ECODESIGN TEST CERTIFICATE

Extract of report no.: 300-ELAB-2467

Manufacturer: NBE Production A/S
Kjeldgaardsvej 2, 9300 Sæby
CVR nr. 34890323

P nr. 1018144723

Product: Biofuel boiler



**DANISH
TECHNOLOGICAL
INSTITUTE**

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
Phone +45 72 20 10 00
Fax +45 72 20 10 19
Info@teknologisk.dk

Model: BS1016

Procedure: Testing according to EN 303-5:2012

Requirements: Commission regulation (EU) No. 2015/1189, Annex II, Article 1

Stoking princ.: Automatic **Fuel:** Biomass

Testing has been carried out with wood pellets (C1) with the following results:

TEST RESULTS

Measurement	Unit	Result	Limits
Nominal heat output	kW	13,4	
CO at 10% O ₂	mg/m _n ³	83	
OGC at 10% O ₂	mg/m _n ³	< 6	
Dust at 10% O ₂	mg/m _n ³	27	
NO _x at 10% O ₂	mg/m _n ³	146	
Efficiency	%	93,2	
Minimum heat output	kW	3,6	
CO at 10% O ₂	mg/m _n ³	275	
OGC at 10% O ₂	mg/m _n ³	9	
Dust at 10% O ₂	mg/m _n ³	43	
NO _x at 10% O ₂	mg/m _n ³	119	
Efficiency	%	90,0	
Seasonal emissions			
CO at 10% O ₂	mg/m _n ³	247	500
OGC at 10% O ₂	mg/m _n ³	9	20
Dust at 10% O ₂	mg/m _n ³	40	40
NO _x at 10% O ₂	mg/m _n ³	123	200
Seasonal space heating energy efficiency			
η _s	%	79	75
η _{son}	%	83,7	
F1	%	3,0	
F2	%	1,7	

Please note that the stated values are an extract from the test report. For further information please refer to the test report.

Aarhus, 30. April 2020

Anders Pødenphant
B. Sc.