

TEST CERTIFICATE

Extract of report no.: 300-ELAB-2254

Manufacturer: NBE Production A/S
Kjeldgaardsvej 2, 9300 Sæby
CVR nr. 34890323

P nr. 1018144723

Product: Biofuel boiler



**DANISH
TECHNOLOGICAL
INSTITUTE**

Model: BS+ 25

Procedure: Testing according to EN 303-5:2012

Requirements: Commission regulation (EU) No. 2015/1189, Annex II, Article 1

Stoking princ.: Automatic **Fuel:** Biomass

Testing has been carried out with wood pellets (C1) with the following results:

TEST RESULTS

Measurement	Unit	Result	Limits
Nominal heat output	kW	23	
CO at 10% O ₂	mg/m _n ³	254	
OGC at 10% O ₂	mg/m _n ³	< 6	
Dust at 10% O ₂	mg/m _n ³	26	
NO _x at 10% O ₂	mg/m _n ³	144	
Efficiency	%	95,0	
Minimum heat output	kW	6,7	
CO at 10% O ₂	mg/m _n ³	495	
OGC at 10% O ₂	mg/m _n ³	19	
Dust at 10% O ₂	mg/m _n ³	32	
NO _x at 10% O ₂	mg/m _n ³	138	
Efficiency	%	92,9	
Seasonal emissions			
CO at 10% O ₂	mg/m _n ³	459	500
OGC at 10% O ₂	mg/m _n ³	< 17	20
Dust at 10% O ₂	mg/m _n ³	31	40
NO _x at 10% O ₂	mg/m _n ³	139	200
Seasonal space heating energy efficiency			
η _s	%	82,3	77
η _{son}	%	86,3	
F1	%	3,0	
F2	%	1,0	

Please note that the stated values are an extract from the test report. For further information please refer to the test report.

Aarhus, 17. January 2018

Anders Pødenphant
B. Sc.

This certificate has been conducted and calculated on the basis of an accredited test report performed by the test institute under the accreditation of DANAK member of EA and ILAC.

ED Certificate 300-ELAB-2254